



NOTE:
 RIPRAP TO BE FORMED ON UNDISTURBED
 SOIL CUT TO GRADE. IF TO BE PLACED ON
 FILL, ALL FILL SHALL BE PLACED ON BENCHES
 CUT IN UNDISTURBED SOIL AND FILLED IN
 8" LOOSE LIFTS, EACH COMPACTED TO 95%
 STANDARD PROCTOR DENSITY. THE FILL SO
 COMPACTED SHALL THEN BE CUT TO GRADE.



**CITY OF
 DECATUR**

DRAINAGE SYSTEM CONSTRUCTION DETAILS
STORM SEWER CONCRETE RIPRAP

REVISED MAR 2000
 SCALE: 3/8" = 1'
 SHEET: **D-11**